




Controller Model: **API, GE Fanuc VersaMax,  
QuickSilver SilverMax**

Maple OIT Model: **OIT3100 and OIT4100 Series**

Communication Type: **RS-232 with DE9 connector at Controller**

Use the wiring diagram and illustration to assemble a communication cable for use with an API, GE Fanuc VersaMax or QuickSilver SilverMax controller.

**Note:** The QuickSilver SilverMax communication cable is connected to the QuickSilver Y cable (P/N: QCI-EC-SMY9-4-00).



**NOTES:**

- 1 Connect shield wire to the metal housing of the RJ-45 and the DE9 connector.

