




Controller Model: **Entertron Industries Controllers**
 Maple OIT Model: **OIT3100 and OIT4100 Series**
 Communication Type: **RS-232 with Leads at Controller**

Use the wiring diagram and illustration to assemble a communication cable for use with an Entertron Industries SK1600-R-SA, Smart-Pak, Smart-Pak Plus, or Elite 2000 controller.



OIT END

CONTROLLER END

NOTES:

- 1) Twist together 18 AWG green wire and shield wire. Solder wires and insulate with heatshrink to avoid shorting.
- 2) Connect shield wire to the metal housing of the RJ-45 connector.

