




Controller Model: **Tolomatic Axidyne AxiomPlus PV Series**

Maple OIT Model: **BLU300 Series**

Communication Type: **RS-232 with DE9 connector at Controller**

Use the wiring diagram and illustration to assemble a communication cable for use with a Tolomatic Axidyne AxiomPlus PV Series controller.



NOTES:

- 1 Solder shield wire to the DE9S connector metal shell at both ends of the cable. Install heatshrink tubing over the shield wire to avoid shorting.

